

ENERGY RELATED PRODUCT DIRECTIVE

This product meets the Ecodesign Requirements for an electric fixed local space heater.
Commission regulation (EU)2015/1188

Model Identifier(s):		QRAD 050	QRAD 075	QRAD 100	QRAD 150	QRAD 200	Unit
Heat output							
Nominal heat output	P _{nom}	0.5	0.75	1.0	1.5	2.0	kW
Minimum heat output (indicative)	P _{min}	0.5	0.75	0.0	0.0	0.0	kW
Maximum continuous heat output	P _{max,c}	0.5	0.75	1.0	1.5	2.0	kW

Auxiliary electricity consumption							
At Nominal heat output	e _{lmax}	0.00	0.00	0.00	0.00	0.00	kW
At Minimum heat output	e _{lmin}	0.00	0.00	0.00	0.00	0.00	kW
In Standby Mode	e _{lSB}	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	kW

Type of heat output / room temperature control	
With electronic room temperature control plus week timer	Yes
Room temperature control with open window detection	Yes
With adaptive start control	Yes

Contact details:

Glen Dimplex Heating and Ventilation

Millbrook House, Grange Drive, Hedge End, Southampton, SO30 2DF

TEL: 0344 879 3588